

LEAD IN DRINKING WATER ADDENDUM

To:	Mr. Dan Poulliott Jordan Elbridge CSD 9 N. Chappell St. PO Box 902 Jordan, NY 13080 dpoulliott@jecsd.org
Conducted by:	Paradigm Environmental, LLC 6950 E. Genesee St. Fayetteville, NY 13066
Inspector:	Peter Koslowsky LBP-R-8359-3
Original Sample Date:	June 7, 2025
Retest Dates:	7/30/2025 & 8/19/2025
Original Report Date:	July 7, 2025
Addendum Date:	9/8/2025
Project:	Jordan Elbridge Central School District

Jordan Elbridge Central School District retained Paradigm Environmental, LLC to conduct the required Lead in Drinking Water sampling efforts.

The sampling results were reviewed and summarized for this Lead in Drinking Water assessment.

Water Sampling Protocols: Prior to sampling, the water is not used and allowed to stagnate in the pipes for a period of 8-18 hours. During this time, water is not allowed to be drawn from any fixture. At the request of the client, the drinking water sampling was conducted in compliance with the NYSDOH Regulations as set forth in the [Lead Testing in School Drinking Water Program Guidance Manual](#) (K-12 Schools) and USEPA Requirements for Lead Sampling and Testing Protocols.

Lead-in-drinking water testing is required for all NYS Public Schools and BOCES every three (3) years. The requirements are detailed in the NYS Department of Health (“NYDOH”) Regulation, Lead Testing in School Drinking Water (10 NYCRR Subpart 67-4).

LEAD IN DRINKING WATER REVIEW

Analytical Protocols: The water samples were submitted to Accurate Analytical Testing, LLC (“Accurate”) for analysis. The following USEPA Methodologies were used to prepare and analyze the drinking water samples for Lead:

Drinking Water Sample Preparation USEPA Method 200.7/200.8
 Lead by ICP-MS USEPA Method 200.8 Rev. 5.4

Accurate Analytical Testing, LLC is an environmental laboratory certified by the NYSDOH Environmental Laboratory Approval Program (ELAP).

Jordan Elbridge Central School District (JECSD): A total of 139 locations were originally sampled from The Elementary School, Middle School & High School with “First Draw” samples being collected directly from the fixtures, on June 7, 2025. 36 taps were tested at the High School; 48 taps were tested at the Middle School; & 55 taps were tested at the Elementary School. The sampling plan was created by a representative from JECSD and was carried out by Paradigm. Of the taps that tested high for lead, 3 taps were retested. The Tables below show the results of the retests.

The following tables highlight results that were elevated (greater than 5 ppb).

JECSD Middle School Results of the Retesting of Elevated Taps				
Sample ID	Date	Floor	Location	Lead Level (ppb)
MS125 C	7/30/2025	1	Kitchen, 3-Bay Pot Sink-Left	3.8

JECSD Elementary School Results above NYSDOH Action Level (5 ppb)				
Sample ID	Date	Floor	Location	Lead Level (ppb)
EE133B	7/30/2025	1	Kitchen, 3-Bay Sink-Left	2.1
EE133C	8/19/2025	1	Kitchen, 3-Bay Sink-Right	<2.0

A complete list of taps that were tested are on the lab report dated July 7, 2025.

Reporting Obligations in K-12 Schools

Within 1 business day of receipt of this report, report any and all exceedances (lead greater than 5 ppb) to the local health department.

Within 10 business days of receipt of this report, report all exceedances to staff, parents and guardians in writing.

Report test results (including post-remediation results) in the Department’s electronic reporting system, HERDS accessed through HCS. This information is posted on the Department’s website for the public.

Within 6 weeks of receipt of this report post numeric test results of all lead testing and information about remediation actions taken to address outlets where lead exceeded the action level on the school’s website. This should remain posted on the school’s website for the duration of the compliance period (i.e. 2020-2024)

LEAD IN DRINKING WATER REVIEW

Measures to Reduce Lead in Drinking Water:

Flush your pipes before drinking: The more time water has been sitting in your home's pipes, the more lead it may contain. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

Only use cold water for eating and drinking: Use only water from the cold-water tap for drinking, cooking, and especially for making baby formula. Hot water is likely to contain higher levels of lead. Run cold water until it becomes as cold as it can get.

Use water filters or treatment devices:

Many water filters and water treatment devices are certified by independent organizations for effective lead reduction. Devices that are not designed to remove lead will not work. Verify the claims of manufacturers by checking with independent certifying organizations that provide lists of treatment devices they have certified:

[NSF International](#)

[Water Quality Association](#)

Replace existing plumbing: Although not economically feasible in most instances, removal and replacement of the household plumbing system is the only way to truly rid the home of lead in the plumbing.

Note that boiling water will NOT get rid of lead contamination.

Please see attached lab reports.

Sincerely,

A handwritten signature in black ink that reads "Peter Koslowsky". The signature is written in a cursive style with a large initial "P" and "K".

Peter Koslowsky
Paradigm Environmental, LLC



PARADIGM
ENVIRONMENTAL, LLC.

Friday, August 8, 2025

Jordan Elbridge CSD
9 N. Chappel Street
PO Box 902
Jordan, NY 13080
Dan Poulliott
dpoulliott@jecsd.org

Re: Middle School: Lead in Drinking Water Analytical Services

Paradigm Job #2364-25S

Please See Enclosed Results

For your information, The EPA National Primary Drinking Water Regulation Control of Lead and Copper (40 CFR Part 141 Subpart I) defines the Action Level of Lead in drinking water to be more than 0.015 mg/L (ppm).

If you have any additional questions concerning this report, please do not hesitate to call me at 315-455-2714 or email me at kjoyce@paradigmenvllc.com. Thank you.

Sincerely,

Kathleen Joyce
Kathleen Joyce
Paradigm Environmental, LLC.

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Paradigm Env. LLC. 6950 East Genesee Street Fayetteville, NY 13066 Attn : Kathleen Joyce Email : kjoyce@paradigmenvllc.com Phone : 845-462-1466 Fax :	AAT Project : 1189893 Sampling Date : 07/30/2025 Date Received : 07/31/2025 Date Analyzed : 08/07/2025 Date Reported : 08/07/2025	Client Project : S25-0018 Collected By: PETER KOSLOWSKY WSSN : NP Project Location : JECSD-MIDDLE SCHOOL 9 N CHAPPEL ST JORDAN NY
---	--	--

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10663668	MS 125C	KIT 3 BAY POT SINK LEFT	DW	840	0.0038	0.0020	Below

Analyst Signature



Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : Paradigm Env. LLC.
6950 East Genesee Street
Fayetteville, NY 13066

AAT Project : 1189893
Client Project : S25-0018
Date Reported 08/07/2025

Attn : Kathleen Joyce Email : kjoyce@paradigmenvllc.com
Phone : 845-462-1466

Project Location : JECSD-MIDDLE SCHOOL 9 N CHAPPEL ST JORDAN NY

Sample	Client Code	Analysis Requested	Completed	Analyst
10663668	MS 125C	Pb/Cu in Drinking Water	08/07/2025	Joseph Kenwabikise

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



PARADIGM
ENVIRONMENTAL, LLC.

Monday, August 11, 2025

Jordan Elbridge CSD
9 N. Chappel Street
PO Box 902
Jordan, NY 13080
Dan Poulliott
dpoulliott@jecsd.org

Re: Elementary School: Lead in Drinking Water Analytical Services

Paradigm Job #2365-25S

Please See Enclosed Results

For your information, The EPA National Primary Drinking Water Regulation Control of Lead and Copper (40 CFR Part 141 Subpart I) defines the Action Level of Lead in drinking water to be more than 0.015 mg/L (ppm).

If you have any additional questions concerning this report, please do not hesitate to call me at 315-455-2714 or email me at kjoyce@paradigmenvllc.com. Thank you.

Sincerely,

Kathleen Joyce
Kathleen Joyce
Paradigm Environmental, LLC.



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Paradigm Env. LLC.
 6950 East Genesee Street
 Fayetteville, NY 13066

Attn : Kathleen Joyce **Email :** kjoyce@paradigmenvllc.com
Phone : 845-462-1466 **Fax :**

AAT Project : 1189892
Sampling Date : 07/30/2025
Date Received : 07/31/2025
Date Analyzed : 08/07/2025
Date Reported : 08/08/2025

Client Project : S25-0018 **Collected By:** PETER KOSLOWSKY

WSSN : NP

Project Location : JECSD-ELEMENTARY SCHOOL-130 E MAIN ST ELBRIDGE NY

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10663666	EE 133B	KIT 3 BAY SINK LEFT	DW	825	0.0021	0.0020	Below
10663667	EE 133C	KIT 3 BAY SINK RIGHT	DW	827	0.04047	0.0020	Above

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 08/08/2025

AAT Project: 1189892



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : Paradigm Env. LLC.
6950 East Genesee Street
Fayetteville, NY 13066

AAT Project : 1189892
Client Project : S25-0018
Date Reported 08/08/2025

Attn : Kathleen Joyce Email : kjoyce@paradigmenvllc.com
Phone : 845-462-1466

Project Location : JECSD-ELEMENTARY SCHOOL-130 E MAIN ST ELBRIDGE NY

Sample	Client Code	Analysis Requested	Completed	Analyst
10663666	EE 133B	Pb/Cu in Drinking Water	08/07/2025	Joseph Kenwabikise
10663667	EE 133C	Pb/Cu in Drinking Water	08/07/2025	Joseph Kenwabikise

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



30105 BEVERLY RD.
ROMULUS MI 48174
(734) 699-LABS (5227)
FAX: (734) 699-8407

Website: www.accurate-test.com

Email: customersupport@accurate-test.biz



LAB #10101010

SUBMITTING COMPANY
Paradigm Environmental, LLC

Office: 315-455-2714

Fax:

Cell:

Email: kjoyce@paradigmenvllc.com

PROJECT NUMBER: S25-0018 SAMPLING DATE: 7/30/2025

PROJECT ADDRESS: JECSD - Elementary School 130 E. Main St, Elbridge NY

PERSON COLLECTING the SAMPLES: Peter Koslowsky

REQUESTED ANALYSIS: **Drinking Water**

WSSN

LEAD COPPER BOTH

TURNAROUND TIME (please check one)
 24 Hour () 48 Hour ()
 72 Hour () 5 Days (X)

If no TAT is indicated, default is 5 Days

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE or PURPOSE *	TIME	VOLUME	CLIENT COMMENTS
W05-1008	EE 133B	Kitchen 3 Bay Sink - left	DW	825	250ml	SAMPLES SHIPPED
	EE 133C	Kitchen 3 Bay Sink - right	DW	827	250ml	SAMPLES ACIDIFIED Y N
						NY STATE SAMPLES X
						(Check here)
						SAMPLE CONDITION
						SEALS INTACT Y N
						CONTAINERS LABELED Y N
						RECVD & ACCEPTED Y N
						SAMPLES ACIDIFIED Y N
						LAB REMARKS

SAMPLES RELINQUISHED BY: *[Signature]*

SAMPLES RECEIVED BY: *[Signature]*


LAB PROJECT NUMBER: *11825*

DATE: *JUL 31 2025*

TIME: *a*

By submitting samples to AAT, the client agrees to AAT's terms and conditions.
AAT is not responsible for shipping delays

* Sample Type or Purpose -- Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)





PARADIGM
ENVIRONMENTAL, LLC.

Monday, September 1, 2025

Jordan Elbridge CSD
9 N. Chappel Street
PO Box 902
Jordan, NY 13080
Dan Poulliott
dpoulliott@jecsd.org

Re: Elbridge Elementary School – 130 Main St, Elbridge, NY: Lead in Drinking Water Analytical Services

Paradigm Job #2603-25S

Please See Enclosed Results

For your information, The EPA National Primary Drinking Water Regulation Control of Lead and Copper (40 CFR Part 141 Subpart I) defines the Action Level of Lead in drinking water to be more than 0.015 mg/L (ppm).

If you have any additional questions concerning this report, please do not hesitate to call me at 315-455-2714 or email me at kjoyce@paradigmenvllc.com. Thank you.

Sincerely,

Kathleen Joyce

Kathleen Joyce
Paradigm Environmental, LLC.

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Paradigm Env. LLC. 6950 East Genesee Street Fayetteville, NY 13066 Attn : Kathleen Joyce Email : kjoyce@paradigmenvllc.com Phone : 845-462-1466 Fax :	AAT Project : 1196434 Sampling Date : 08/19/2025 Date Received : 08/20/2025 Date Analyzed : 08/25/2025 Date Reported : 08/26/2025	Client Project : S25-0118 Collected By: PETER KOSLOWSKY WSSN : NP Project Location : ELBRIDGE ELEMENTARY SCHOOL-130 E MAIN ST ELBRIDGE NY
---	--	--

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10714343	EE133C	KITCHEN 3-BAY SINK RIGHT RETEST 2	DW		<0.0020	0.0020	Below

Analyst Signature



Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : Paradigm Env. LLC.
6950 East Genesee Street
Fayetteville, NY 13066

AAT Project : 1196434
Client Project : S25-0118
Date Reported 08/26/2025

Attn : Kathleen Joyce Email : kjoyce@paradigmenvllc.com
Phone : 845-462-1466

Project Location : ELBRIDGE ELEMENTARY SCHOOL-130 E MAIN ST ELBRIDGE NY

Sample	Client Code	Analysis Requested	Completed	Analyst
10714343	EE133C	Pb/Cu in Drinking Water	08/25/2025	Joseph Kenwabikise

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



30105 BEVERLY RD.
 ROMULUS MI 48174
 (734) 699-LABS (5227)
 FAX: (734) 699-8407



Website: www.accurate-test.com
 Email: customersupport@accurate-test.biz

SUBMITTING COMPANY
 Paradigm Environmental, LLC
 6950 E. Genesee St.
 Foyetteville, NY 13066
 Katie Joyce

CONTACT INFORMATION
 Office: 315-455-2714
 Fax:
 Cell:
 Email: kjoyce@paradigmenvllc.com

PROJECT NUMBER: S25-0118 SAMPLING DATE: 8/19/2025

PROJECT ADDRESS: Elbridge Elementary School-130 E. Main St., Elbridge, NY

PERSON COLLECTING the SAMPLES: Peter Koslowsky

REQUESTED ANALYSIS: **Drinking Water**

LEAD COPPER BOTH

TURNAROUND TIME (please check one)
 24 Hour () 48 Hour ()
 72 Hour () 5 Days (X)

If no TAT is indicated, default is 5 Days

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE or PURPOSE *	TIME	VOLUME	CLIENT COMMENTS
101133C	EE133C	Kitchen 3-Bay Sink Right retest #2	DW		250 ml	SAMPLES SHIPPED SAMPLES ACIDIFIED Y N NY STATE SAMPLES X (Check here)
						SAMPLE CONDITION SEALS INTACT Y N CONTAINERS LABELED Y N RECYD & ACCEPTED Y N SAMPLES ACIDIFIED Y N
						LAB REMARKS

SAMPLES RELINQUISHED BY: *[Signature]*

SAMPLES RECEIVED BY: *[Signature]*

LAB PROJECT NUMBER: 1101334

DATE: AUG 20 2025

TIME: AM PM

By submitting samples to AAT, the client agrees to AAT's terms and conditions.
 AAT is not responsible for shipping delays

* Sample Type or Purpose -- Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)



United States Environmental Protection Agency

This is to certify that



Paradigm Environmental, LLC

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires April 25, 2028

LBP-F201419-3

Certification #

May 15, 2025

Issued On

Marc Edmonds, Chief

Risk Assessment Management Branch 2.

United States Environmental Protection Agency

This is to certify that



Peter K. Koslowsky

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires February 04, 2028

LBP-R-8359-3

Certification #

February 05, 2025

Issued On

Ben Conetta, Manager

Chemicals and Multimedia Programs Branch





AIHA Laboratory Accreditation Programs, LLC

SCOPE OF ACCREDITATION

Accurate Analytical Testing, LLC

30105 Beverly Road, Romulus, MI 48174

Laboratory ID: LAP-100986

Issue Date: 10/01/2023

Expire Date: 10/01/2025

The laboratory is approved for those specific field(s) of testing/methods listed in the table below. Clients are urged to verify the laboratory's current accreditation status for the particular field(s) of testing/Methods, since these can change due to proficiency status, suspension and/or withdrawal of accreditation.

The EPA recognizes the AIHA LAP, LLC ELLAP program as meeting the requirements of the National Lead Laboratory Accreditation Program (NLLAP) established under Title X of the Residential Lead-Based Paint Hazard Reduction Act of 1992 and includes paint, soil and dust wipe analysis. Air and composited wipes analyses are not included as part of the NLLAP.

Environmental Lead Laboratory Accreditation Program (ELLAP)

Initial Accreditation Date: 02/01/2004

Component, parameter, characteristic, material, or product tested	Technology sub-type/Detector	Method	Method Description <i>(for internal methods only)</i>
Airborne Dust	AA	EPA SW-846 7000B	N/A
		NIOSH 7082	N/A
Paint	AA	EPA SW-846 3050B	N/A
		EPA SW-846 7000B	N/A
Settled Dust by Wipe	AA	EPA SW-846 7000B	N/A
		NIOSH 7082	N/A
Soil	AA	EPA SW-846 3050B	N/A
		EPA SW-846 7000B	N/A

A complete listing of currently accredited ELLAP laboratories is available on the AIHA LAP, LLC website at: <http://www.aihaaccreditedlabs.org>



AIHA Laboratory Accreditation Programs, LLC

acknowledges that

Accurate Analytical Testing, LLC
30105 Beverly Road, Romulus, MI 48174
Laboratory ID: LAP-100986

along with all premises from which key activities are performed, as listed above, has fulfilled the requirements of the AIHA Laboratory Accreditation Programs, LLC (AIHA LAP) accreditation to the ISO/IEC 17025:2017 international standard, General Requirements for the Competence of Testing and Calibration Laboratories in the following:

LABORATORY ACCREDITATION PROGRAMS

- | | | |
|-------------------------------------|----------------------------|---|
| <input type="checkbox"/> | INDUSTRIAL HYGIENE | Accreditation Expires: |
| <input checked="" type="checkbox"/> | ENVIRONMENTAL LEAD | Accreditation Expires: October 01, 2025 |
| <input type="checkbox"/> | ENVIRONMENTAL MICROBIOLOGY | Accreditation Expires: |
| <input type="checkbox"/> | FOOD | Accreditation Expires: |
| <input type="checkbox"/> | UNIQUE SCOPES | Accreditation Expires: |
| <input type="checkbox"/> | BE FIELD/MOBILE | Accreditation Expires: |

Specific Field(s) of Testing/Method(s) within each Accreditation Program for which the above named laboratory maintains accreditation is outlined on the attached Scope of Accreditation. Continued accreditation is contingent upon successful on-going compliance with ISO/IEC 17025:2017 and AIHA LAP requirements. This certificate is not valid without the attached Scope of Accreditation. Please review the AIHA LAP website (www.aihaaccreditedlabs.org) for the most current Scope.

Cheryl O Morton
Managing Director, AIHA Laboratory Accreditation Programs, LLC

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

*MR. ROBERTA A. THEYS
ACCURATE ANALYTICAL TESTING, LLC
30105 BEVERLY RD.
ROMULUS, MI 48174*

NY Lab Id No: 11864

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*

Metals I

Lead, Total EPA 7000B

Miscellaneous

Lead in Dust Wipes EPA 7000B

Lead in Paint EPA 7000B

Sample Preparation Methods

AAT SOP S205, rev AE

AAT SOP S218 rev K

AAT SOP S235 rev G

AAT SOP S207, rev. X

AAT SOP S228, rev. G

EPA 3050B

ASTM E-1644-17



Serial No.: 70666

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

*MR. ROBERTA A. THEYS
ACCURATE ANALYTICAL TESTING, LLC
30105 BEVERLY RD.
ROMULUS, MI 48174*

NY Lab Id No: 11864

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Copper, Total	EPA 200.5
Lead, Total	EPA 200.5



Serial No.: 70665

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

